



**RIO METRO**  
REGIONAL TRANSIT DISTRICT



NEW MEXICO  
**RAIL RUNNER**  
EXPRESS

# **Rio Metro Regional Transit District**

## **REQUEST FOR BIDS**

Retention Pond Tree and Brush Removal and Cleaning

### **ADDENDUM #2**

**Issued December 4, 2019**

Issued: November 27, 2019

Procurement No.: RFB #2020-03

Proposal Due Date/Time: December 10, 2019, 2:00 PM (MST)

Addendum #2

RFB #2020-03

Retention Pond Tree and Brush Removal and Cleaning

Addenda #2 is issued to: correction to the answer for question from vendor

- 1) By "Removal of Trees" what means of removal are you referring to? Are they to be saw cut and the biomass removed/hailed away? Or are they to be Mechanically Extracted and the biomass removed/hailed away?

~~Trees should be saw cut and the biomass removed.~~

Correction: trees should be mechanically extracted and the biomass removed. Divots should be filled with existing / removed soil and surface smoothed. Compaction is not required.